
































Tone table

ASM

STAGE 1 S1	Tone type	Frequency Hz	Pictogram	Repeat rate	Specific application	max dB	STAGE 2 S2	STAGE 3 S3
Tone 01	continuous	660			Swedish Alarm	108	Tone 16	Tone 12
Tone 02	continuous	1000			PFEER toxic gas	109	Tone 16	Tone 25
Tone 03	continuous	2400				113	Tone 21	Tone 17
Tone 04	intermittent	420		0,625 s on / 0,625 s off	Australian alert AS1670	105	Tone 21	Tone 01
Tone 05	intermittent	660		1,8 s on / 1,8 s off	Swedish Alarm	107	Tone 21	Tone 01
Tone 06	intermittent	660		0,15 s on / 0,15 s off	Swedish Alarm	107	Tone 16	Tone 01
Tone 07	intermittent	970		1 s on, 1 s off	PFEER Alarm, BS5839-1:2002	109	Tone 18	Tone 01
Tone 08	intermittent	970 (950)		0,5 s on/0,5 s off x 3 dann 1,5 s off	ISO 8201 low tone, US Temporal	109	Tone 16	Tone 03
Tone 09	intermittent	800		0,25 s on / 1 s off	Swedish Alarm SS 031711	107	Tone 27	Tone 03
Tone 10	intermittent	700		0,15 s on / 0,15 s off, total 1 min.	Industrial alarm Germany	107	Tone 18	Tone 02
Tone 11	intermittent	720		0,7 s on / 0,3 s off		108	Tone 02	Tone 29
Tone 12	intermittent	2400		0,5 s on / 0,5 s off	ISO 8201 high tone, US Temporal	113	Tone 03	Tone 01
Tone 13	intermittent	2850		0,5 s on / 0,5 s off x 3 dann 1,5 s off	AFNOR France, NFS 32-001	110	Tone 03	Tone 17
Tone 14	alternating	440 - 554		0,4 s (440Hz) / 0,1 s (554Hz)	Swedish Alarm	106	Tone 16	Tone 01
Tone 15	alternating	554 - 440		1 Hz		106	Tone 01	Tone 16
Tone 16	alternating	800 - 1000		2 Hz		109	Tone 02	Tone 09
Tone 17	alternating	2400 - 2900		2 Hz		113	Tone 03	Tone 01
Tone 18	alternating	1000 - 2000		1 Hz	Singapore	110	Tone 02	Tone 03
Tone 19	sweeping	500 - 1500		10 Hz		109	Tone 02	Tone 01
Tone 20	sweeping	150 - 1000		rising 10 s, 40 s on, falling 10 s	Industrial alarm Germany	109	Tone 01	Tone 29
Tone 21	continuous	400		simulated Horn		104	Tone 16	Tone 02
Tone 22	sweeping	500 - 1200		rising in 3,75 s/ 0,25 s off	Australian evacuation AS 2220	109	Tone 02	Tone 09
Tone 23	sweeping	500 - 1200		rising in 3,5 s/ 0,5 s off	Netherlands NEN 2575:2000	109	Tone 02	Tone 09
Tone 24	sweeping	500 - 1200		0,5 s on/0,5 s off x 3 / 1,5 s off	Australian evacuation AS1670	109	Tone 02	Tone 09
Tone 25	abfallend	1200 - 500		1 Hz	German evacuation DIN 33404-3	109	Tone 02	Tone 32
Tone 26	sweeping	500 - 1200		0,3 Hz		109	Tone 01	Tone 32
Tone 27	sweeping	1400 - 1600		rising in 1 s/falling in 0,5 s	NFC 48-265	111	Tone 02	Tone 09
Tone 28	sweeping	2400 - 2900		1 Hz		113	Tone 17	Tone 03
Tone 29	bell					109	Tone 16	Tone 02
Tone 30	slow rise	500 - 2400		siren rising 3 s, then continuous 2400 Hz		113	Tone 16	Tone 01
Tone 31	slow rise	300 - 1200		siren rising 3 s, then continuous 1200 Hz		110	Tone 16	Tone 01
Tone 32	chime	970 - 800		repeating ding-dong, 1 Hz		109	Tone 29	Tone 01