



## EMC Declaration of Conformity(DoC)

**No:** WT168003776

**Applicant:** Accuenergy (Canada)INC

**Address:** 2 Lansing Square, Suite 1001, Toronto, ON M2J 4P8, Canada

has successfully demonstrated that its product

**Product:** three-phase DIN-Rail multifunction meter

**Model:** AcuRev1300,AcuRev1301,AcuRev1302,AcuRev1303,AcuRev1304,AcuRev1310,  
AcuRev1311,AcuRev1312,AcuRev1313,AcuRev1314

**Brand:** Accuenergy, AcuRev

are compliant with

**EMC:** EN55011:2009+A1:2010 EN 61000-3-2:2014  
EN61000-6-2:2005+AC:2005 EN 61000-3-3:2013

This certificate of compliance shows that the tested sample technically complies with essential requirements as given in the EMC Directive 2014/30/EU. The certificate applies to the tested sample above mentioned only and shall not imply an assessment of the whole production.



Authorized Signer



Issued Date: Aug. 07, 2016

# EMC TEST REPORT

For

**three-phase DIN-Rail multifunction meter**

**Model Number:**

**AcuRev1300,AcuRev1301,AcuRev1302,AcuRev1303,AcuRev1304,AcuRev1310,AcuRev1311,AcuRev1312,AcuRev1313,AcuRev1314**



**Report Number : WT168003776**

Test Laboratory : Shenzhen Academy of Metrology and Quality Inspection  
National Digital Electronic Product Testing Center  
Site Location : NETC Building, No.4 Tongfa Rd., Xili, Nanshan, Shenzhen, China  
Tel : 0086-755-86928965  
Fax : 0086-755-86009898-31396  
Web : [www.smq.com.cn](http://www.smq.com.cn)

## TEST REPORT DECLARATION

Applicant : Accuenergy (Canada)INC  
Address : 2 Lansing Square, Suite 1001, Toronto, ON M2J 4P8, Canada

Manufacturer : Beijing Accuenergy Technology Co.,Ltd.  
Address : No.12,FengRun East Road,YongFeng Industrial Park,Haidian District, Beijing, China100094  
Factory : Beijing Accuenergy Technology Co.,Ltd.  
Address : No.12,FengRun East Road,YongFeng Industrial Park,Haidian District, Beijing, China100094

EUT Description : three-phase DIN-Rail multifunction meter

Model Number : AcuRev1300,AcuRev1301,AcuRev1302,AcuRev1303, AcuRev1304,AcuRev1310,AcuRev1311,AcuRev1312, AcuRev1313,AcuRev1314

Trade Mark : Accuenergy, AcuRev  
Serial Number : ---

Test Standards:

**EN55011:2009+A1:2010**  
**EN61000-6-2:2005+AC:2005**  
**EN 61000-3-2:2014**  
**EN 61000-3-3:2013**

The EUT described above is tested by Shenzhen Academy of Metrology and Quality Inspection EMC Laboratory to determine the maximum emissions from the EUT and ensure the EUT to be compliance with the immunity requirements of the EUT. Shenzhen Academy of Metrology and Quality Inspection EMC Laboratory is assumed full responsibility for the accuracy of the test results. . Also, this report shows that the EUT technically complies with essential requirements as given in **Directive 2014/30/EU**.

The test report is valid for above tested sample only and shall not be reproduced in part without written approval of the laboratory.

Project Engineer: 施昌达 Date: July. 07, 2016  
(Shi Changda)

Checked by: 杨东平 Date: July. 07, 2016  
(Yang DongPing)

Approved by: 林斌 Date: July. 07, 2016  
(Lin Bin)

## TABLE OF CONTENTS

<b>TEST REPORT DECLARATION</b> .....	<b>2</b>
<b>1. TEST RESULTS SUMMARY</b> .....	<b>5</b>
<b>2. GENERAL INFORMATION</b> .....	<b>6</b>
2.1. Report information.....	6
2.2. Laboratory Accreditation and Relationship to Customer.....	6
2.3. Measurement Uncertainty.....	7
<b>3. PRODUCT DESCRIPTION</b> .....	<b>8</b>
3.1. EUT Description.....	8
3.2. Block Diagram of EUT Configuration.....	8
3.3. Operating Condition of EUT.....	8
3.4. Support Equipment List.....	8
3.5. Test Conditions.....	9
3.6. Modifications.....	9
3.7. Performance Criterion.....	9
<b>4. TEST EQUIPMENT USED</b> .....	<b>10</b>
4.1. Test Equipment Used to Measure Conducted Disturbance.....	10
4.2. Test Equipment Used to Measure Radiated Disturbance.....	10
4.3. Test Equipment Used to Measure Harmonic Current /Voltage Fluctuation and Flicker	10
4.4. Test Equipment Used to Measure Electrostatic Discharge Immunity.....	10
4.5. Test Equipment Used to Measure Electrical Fast Transient/Burst Immunity....	10
4.6. Test Equipment Used to Measure Radio Frequency Electromagnetic Fields Immunity.....	11
4.7. Test Equipment Used to Measure Surge Immunity.....	11
4.8. Test Equipment Used to Measure Conducted Immunity.....	11
4.9. Test Equipment Used to Measure Voltage Dips and Interruptions Immunity....	11
4.10. Test Equipment Used to Measure Power frequency magnetic field Immunity	11
<b>5. CONDUCTED DISTURBANCE TEST</b> .....	<b>12</b>
5.1. Test Standard and Limit.....	12
5.2. Test Procedure.....	12
5.3. Test Arrangement.....	12
5.4. Test Data.....	12
<b>6. RADIATED DISTURBANCE TEST</b> .....	<b>14</b>
6.1. Test Standard and Limit.....	14
6.2. Test Procedure.....	14
6.3. Test Arrangement.....	14
6.4. Test Data.....	14
<b>7. HARMONIC CURRENT EMISSION TEST</b> .....	<b>16</b>
7.1. Test Standard and Limit.....	16
7.2. Test Procedure.....	16
7.3. Test Data.....	16

<b>8.</b>	<b>VOLTAGE FLUCTUATION AND FLICKER TEST.....</b>	<b>19</b>
8.1.	Test Standard and Limit.....	19
8.2.	Test Procedure.....	19
8.3.	Test Data .....	19
<b>9.</b>	<b>ELECTROSTATIC DISCHARGE IMMUNITY TEST .....</b>	<b>21</b>
9.1.	Test Requirements .....	21
9.2.	Test Procedure.....	21
9.3.	Test Data .....	21
<b>10.</b>	<b>RADIATED ELECTROMAGNETIC FIELD IMMUNITY TEST .....</b>	<b>23</b>
10.1.	Test Requirements.....	23
10.2.	Test Procedure.....	23
10.3.	Test Data .....	23
<b>11.</b>	<b>ELECTRICAL FAST TRANSIENT/BURST TEST .....</b>	<b>25</b>
11.1.	Test Requirements.....	25
11.2.	Test Procedure.....	25
11.3.	Test Data .....	25
<b>12.</b>	<b>SURGE IMMUNITY TEST .....</b>	<b>27</b>
12.1.	Test Requirements.....	27
12.2.	Test Procedure.....	27
12.3.	Test Data .....	27
<b>13.</b>	<b>CONDUCTED IMMUNITY TEST .....</b>	<b>28</b>
13.1.	Test Requirements.....	28
13.2.	Test Procedure.....	28
13.3.	Test Data .....	28
<b>14.</b>	<b>VOLTAGE DIPS AND INTERRUPTIONS IMMUNITY TEST .....</b>	<b>29</b>
14.1.	Test Requirements.....	29
14.2.	Test Procedure.....	29
14.3.	Test Data .....	29
	<b>APPENDIX I TEST PHOTOS .....</b>	<b>30</b>
	<b>APPENDIX II EUT PHOTOS.....</b>	<b>36</b>

## 1. TEST RESULTS SUMMARY

Table 1 Test Results Summary

Test Items	Test Results
Conducted Disturbance	Pass
Radiated Disturbance	Pass
Harmonic current	N/A
Flicker	Pass
ESD Immunity	Pass
Radiated Electromagnetic Field Immunity	Pass
EFT Immunity	Pass
Surge Immunity	Pass
Conducted Immunity	Pass
Voltage dips and interruptions Immunity	Pass

Remark: "N/A" means "Not applicable."