

DDS-1Y-36L-80A-M Modbus Registers

Modbus RTU default format:
9600 Baud, 8 bit no parity 1 stop bit.
First word high in 32 bit data types.

Registers			
Register address	Register name	Unit	Data type
40001-40002	Total active energy 7 digits max. 9999999	0.1kWh	Unsigned 32 bit
40007 (write only)	Node address (1 to 247)	Address	Unsigned 16 bit